

Confirmation

LEED

On 8 September 2016, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

SikaBond-151 Object

supplied by

Sika Services AG

The sample was supplied as being representative of the manufactured product, and it has been tested as Wood Flooring Adhesive in accordance with the relevant ISO 16000, AgBB, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2016-00331301_A and 392-2016-00331601_XD).

The test results of the tested adhesive indicate that the product qualifies for LEED v4 and/or LEED 2009 specifications on VOC emissions and/or VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of DIBt (October 2010) and AgBB (February 2015), and the formaldehyde limit of 10 µg/m³ after 28 days
- the requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m³ in both office and class room.

VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of SCAQMD rule 1168 (2005)

19 October 2016



Maria Pelle
Chemist



Janne R. Norup
Chemist

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.